

EMC filters

2-line filters SIFI-A for normal insertion loss Rated current 1 to 20 A

Series/Type: B84111A Date: January 2006

© EPCOS AG 2006. Reproduction, publication and dissemination of this data sheet and the information contained therein without EPCOS' prior express consent is prohibited.



SIFI-A for normal insertion loss

Power line filters for 1-phase systems Rated voltage 250 V DC/AC, 50/60 Hz Rated current 1 to 20 A

Alternative version

Series B84111F (SIFI-F) offers a low-cost solution

Construction

- 2-line filters
- Metal case
- Polyurethane potting (UL 94 V-0)

Features

- Compact design
- Optimized leakage current
- Cost-optimized construction
- Also for assembly on top-hat rails
- ENEC10, UL and CSA approval 🚜 🚯

Applications

- Switch-mode power supplies in
 - industrial electronics
 - telecommunications
 - data systems
 - medical equipment
- DC applications

Case styles and terminal styles

Case style A	Tab connectors on face ends, lateral fixing lugs. Particularly suitable for mounting on a shielding wall.
Case style B	Tab connectors on face ends, fixing lugs on face ends.
Case style K	IEC connector as per IEC 60320 C 14 on line side, tab connectors on load side, mounting holes with metric thread.
Case style L	Litz wires on face ends, fixing lugs on face ends

01/06

2

Marking

Marking on component: Manufacturer's logo, ordering code, rated voltage, rated current, rated temperature, climatic category, date code

Minimum marking on packaging: Manufacturer's logo, ordering code



B84111A



SIFI-A for normal insertion loss

Circuit diagram



Technical data and measuring conditions

Rated voltage V _R	250 V DC/AC 50/60 Hz					
Rated current I _R	Referred to 40 °C ambient temperature					
Test voltage V _{test}	1414 V DC, 2 s (line/line) 2700 V DC, 2 s (lines/case)					
Leakage current I _{leak}	At 230 V AC, 50 Hz					
Climatic category (IEC 60068-1)	25/085/21 (-25 °C/+85 °C/21 days damp heat test)					
Approvals	EN 133200, UL 1283, CSA C22.2 No.8					



B84111A

SIFI-A for normal insertion loss

Characteristics and ordering codes

I _R	C _R	L _R	I _{leak}	Case style	Approx. weight	Ordering code	Mounting plate for top-hat rail
A		mн	mΑ		g		(ordering code)
V _R =	250 V DC/AC, 50/6	0 Hz					
1	$2 \times 0.1 \ \mu\text{F}$ (X2)	2 ×	< 0.5	А	80	B84111A0000A010	_
	+	1.5		К	140	B84111A0000K010	—
	$2 \times 4700 \text{ pF}$ (Y2)						
2	$2 \times 0.1 \ \mu\text{F}$ (X2)	2 ×	< 0.5	А	80	B84111A0000A020	_
	+	1.5					
	$2 \times 4700 \text{ pF}$ (Y2)						
3	2 × 0.1 μF (X2)	2 ×	< 0.5	А	80	B84111A0000A030	_
	+	1.5		К	140	B84111A0000K030	—
	$2 \times 4700 \text{ pF}$ (Y2)			L	80	B84111A0000L030	—
6	$2 \times 0.1 \ \mu\text{F}$ (X2)	2 ×	< 0.5	А	110	B84111A0000A060	_
	+	1.8		В	110	B84111A0000B060	C62122A0132B091
	2 × 4700 pF (Y2)			К	140	B84111A0000K060	—
				L	110	B84111A0000L060	—
10	$2 \times 0.1 \ \mu\text{F}$ (X2)	0.82	< 0.5	А	120	B84111A0000A110	—
	+			В	120	B84111A0000B110	C62122A0132B091
	$2 \times 4700 \text{ pF}$ (Y2)			L	120	B84111A0000L110	—
20	$2 \times 0.1 \ \mu\text{F}$ (X2)	2 ×	< 0.5	А	210	B84111A0000A120	_
	+	0.47		В	210	B84111A0000B120	C62122A0132B091
	$2 \times 4700 \text{ pF}$ (Y2)						



B84111A

SIFI-A for normal insertion loss

Case styles and dimensions

Case	I _R	Dimensions (mm)											
style		b ₁	b ₂	b ₃	b ₄	I ₁	I_2	l ₃	I_4	h ₁	h ₂	Litz	Style
	А											mm ²	1015
А	1	45	26.5	60.4	70	50	—	_	76.5	22.3	14		_
К	1	51	—	—	—	63.5	—	—	—	32	—	—	_
A	2	45	26.5	60.4	70	50	—		76.5	22.3	14	—	-
A	3	45	26.5	60.4	70	50	—		76.5	22.3	14	_	_
K	3	51	—	—	—	63.5	—	—	—	32	—	—	—
L	3	45	—	—	—	50	60.4	70	—	28.6	—	0.82	AWG18
A	6	45	26.5	60.4	70	50	_	_	76.5	28.6	20	_	-
В	6	45	26.5	—	—	50	60.4	70	76.5	28.6	20	—	—
K	6	51	—	—	—	63.5	—	—	—	32	—	—	—
L	6	45	—	—	—	50	60.4	70	—	28.6	—	0.82	AWG18
A	10	45	26.5	60.4	70	50	—		76.5	28.6	20	—	-
В	10	45	26.5	—	—	50	60.4	70	76.5	28.6	20	—	—
L	10	45	—	—	—	50	60.4	70	—	28.6	—	1.35	AWG16
A	20	63.5	31.5	74.7	84.5	50.8	—	—	77	38.1	28	—	_
В	20	See dimensional drawing											

Case style A

1 ... 3 A (B84111A0000A010, A020, A030)



6 ... 20 A (B84111A0000A060, A110, A120)



Please read *Cautions and warnings* and *Important notes* at the end of this document.



01/06



SIFI-A for normal insertion loss

Case style B

6 and 10 A (B84111A0000B060, B110)



Case style B

20 A (B84111A0000B120)



Case style K



Case style L



Please read *Cautions and warnings* and *Important notes* at the end of this document.

6 01/06

B84111A



SIFI-A for normal insertion loss

Insertion loss (typical values at $Z = 50 \Omega$)

	unsymmetrical adjacent branches terminated
	unsymmetrical, adjacent branches terminated
- · - · - · - · - · -	common mode, all branches in parallel (asymmetrical)
	differential mode (symmetrical)

Filters for 1 to 3 A



Filters for 10 A



Please read *Cautions and warnings* and *Important notes* at the end of this document.

Filters for 6 A







7



EMC filters

Cautions and warnings

Important information

Please read all safety and warning notes carefully before installing the EMC filter and putting it into operation (see \triangle). The same applies to the warning signs on the filter. Please ensure that the signs are not removed nor their legibility impaired by external influences.

Death, serious bodily injury and substantial material damage to equipment may occur if the appropriate safety measures are not carried out or the warnings in the text are not observed.

Using according to the terms

The EMC filters may be used only for their intended application within the specified values in lowvoltage networks in compliance with the instructions given in the data sheets and the data book. The conditions at the place of application must comply with all specifications for the filter used.

\land Warnings

- It shall be ensured that only qualified persons (electricity specialists) are engaged on work such as planning, assembly, installation, operation, repair and maintenance. They must be provided with the corresponding documentation.
- Danger of electric shock. EMC filters contain components that store an electric charge. Dangerous voltages can continue to exist at the filter terminals for longer than five minutes even after the power has been switched off.
- The protective earth connections shall be the first to be made when the EMC filter is installed and the last to be disconnected. Depending on the magnitude of the leakage currents, the particular specifications for making the protective-earth connection must be observed.
- Impermissible overloading of the EMC filter, such as impermissible voltages at higher frequencies that may cause resonances etc. can lead to destruction of the filter housing.
- EMC filters must be protected in the application against impermissible exceeding of the rated currents by suitable overcurrent protective.



EMC filters

Important notes

The following applies to all products named in this publication:

- 1. Some parts of this publication contain statements about the suitability of our products for certain areas of application. These statements are based on our knowledge of typical requirements that are often placed on our products in the areas of application concerned. We nevertheless expressly point out that such statements cannot be regarded as binding statements about the suitability of our products for a particular customer application. As a rule, EPCOS is either unfamiliar with individual customer applications or less familiar with them than the customers themselves. For these reasons, it is always ultimately incumbent on the customer to check and decide whether an EPCOS product with the properties described in the product specification is suitable for use in a particular customer application.
- 2. We also point out that in individual cases, a malfunction of passive electronic components or failure before the end of their usual service life cannot be completely ruled out in the current state of the art, even if they are operated as specified. In customer applications requiring a very high level of operational safety and especially in customer applications in which the malfunction or failure of a passive electronic component could endanger human life or health (e.g. in accident prevention or life-saving systems), it must therefore be ensured by means of suitable design of the customer application or other action taken by the customer (e.g. installation of protective circuitry or redundancy) that no injury or damage is sustained by third parties in the event of malfunction or failure of a passive electronic component.
- 3. The warnings, cautions and product-specific notes must be observed.
- 4. In order to satisfy certain technical requirements, some of the products described in this publication may contain substances subject to restrictions in certain jurisdictions (e.g. because they are classed as "hazardous"). Useful information on this will be found in our Material Data Sheets on the Internet (www.epcos.com/material). Should you have any more detailed questions, please contact our sales offices.
- 5. We constantly strive to improve our products. Consequently, the products described in this publication may change from time to time. The same is true of the corresponding product specifications. Please check therefore to what extent product descriptions and specifications contained in this publication are still applicable before or when you place an order.

We also **reserve the right to discontinue production and delivery of products**. Consequently, we cannot guarantee that all products named in this publication will always be available.

- 6. Unless otherwise agreed in individual contracts, all orders are subject to the current version of the "General Terms of Delivery for Products and Services in the Electrical Industry" published by the German Electrical and Electronics Industry Association (ZVEI).
- The trade names EPCOS, EPCOS-Jones, Baoke, CeraDiode, CSSP, MLSC, PhaseCap, PhaseMod, SIFI, SIKOREL, SilverCap, SIMID, SIOV, SIP5D, SIP5K, UltraCap, WindCap are trademarks registered or pending in Europe and in other countries. Further information will be found on the Internet at www.epcos.com/trademarks.





Общество с ограниченной ответственностью «МосЧип» ИНН 7719860671 / КПП 771901001 Адрес: 105318, г.Москва, ул.Щербаковская д.З, офис 1107

Данный компонент на территории Российской Федерации

Вы можете приобрести в компании MosChip.

Для оперативного оформления запроса Вам необходимо перейти по данной ссылке:

http://moschip.ru/get-element

Вы можете разместить у нас заказ для любого Вашего проекта, будь то серийное производство или разработка единичного прибора.

В нашем ассортименте представлены ведущие мировые производители активных и пассивных электронных компонентов.

Нашей специализацией является поставка электронной компонентной базы двойного назначения, продукции таких производителей как XILINX, Intel (ex.ALTERA), Vicor, Microchip, Texas Instruments, Analog Devices, Mini-Circuits, Amphenol, Glenair.

Сотрудничество с глобальными дистрибьюторами электронных компонентов, предоставляет возможность заказывать и получать с международных складов практически любой перечень компонентов в оптимальные для Вас сроки.

На всех этапах разработки и производства наши партнеры могут получить квалифицированную поддержку опытных инженеров.

Система менеджмента качества компании отвечает требованиям в соответствии с ГОСТ Р ИСО 9001, ГОСТ РВ 0015-002 и ЭС РД 009

Офис по работе с юридическими лицами:

105318, г.Москва, ул.Щербаковская д.З, офис 1107, 1118, ДЦ «Щербаковский»

Телефон: +7 495 668-12-70 (многоканальный)

Факс: +7 495 668-12-70 (доб.304)

E-mail: info@moschip.ru

Skype отдела продаж: moschip.ru moschip.ru_4

moschip.ru_6 moschip.ru_9