

Level control

→ ENR

- Regulation of two levels (minimum / maximum)
- Monitoring filling (UP) or emptying (DOWN), selected by a switch on the front panel
- Probes supplied with AC current
- Sensitivity adjustable on front panel from 5 k Ω to 100 k Ω



Part numbers


Type	Characteristics	Voltages	Code
ENR	Monitoring filling (UP) Monitoring emptying (DOWN)	24 → 240 V $\sim$	84 870 200

General characteristics

Characteristics		
Supply voltage range	24 → 240 V $\sim$	
Operating range	20.4 → 264 V $\sim$	
Maximum power consumption	$\sim$ 5 VA, --- 1.5 W	
Adjustable sensitivity	5 k Ω → 100 k Ω	
Measurement accuracy (at maximum sensitivity)	$\pm$ 30 %	
Electrode voltage (max)	12 V $\sim$	
Electrode current (maximum)	1 mA	
Maximum cable capacity	10 nF	
Response time high level	300 ms	
Response time low level	500 ms	
Output relay (according to AC1 resistive load)	1 changeover relay 8 A AC max.	
Isolation of contacts and electrodes from power supply	2.5 kV $\sim$	
Operating temperature range (°C)	-20 → +50 °C	
Storage temperature range (°C)	-40 → +70 °C	
Weight (g)	91	


Dimensions (mm)

ENR



Connections


ENR



A1-A2 : power supply

Principles

Monitoring filling or emptying ENR



- ① Maximum level
- ② Minimum level
- ③ Output relay : Down or Up

Operating principle

Monitoring maximum and/or minimum levels of conductive liquids (tap water, sea water, waste water, chemical solutions, coffee, etc).

The principle is based on measuring the apparent resistance of the liquid between two submerged probes. When this value is lower than the preset threshold displayed on the unit's front panel, the output relay changes state. To prevent any occurrences of electrolysis, an AC current is passed through the probes. Areas of application include the agri-food, chemical and other industries.

Adjusting two levels : Minimum/Maximum

The output relay changes state when the level of liquid reaches the maximum electrode, with the minimum electrode submerged. It returns to its initial state when the minimum probe is no longer in contact with the liquid.

Note

If the power break T lasts for 1 second or more, the relay reenergises when in "UP" mode and is de-energised when in "DOWN" mode.

Other information

Note

The probe cable (maximum length 100 metres) does not have to be screened, but avoid mounting it in parallel with the power supply cables. A screened cable can be used with the screening connected to the common terminal.

Данный компонент на территории Российской Федерации

Вы можете приобрести в компании MosChip.

Для оперативного оформления запроса Вам необходимо перейти по данной ссылке:

<http://moschip.ru/get-element>

Вы можете разместить у нас заказ для любого Вашего проекта, будь то серийное производство или разработка единичного прибора.

В нашем ассортименте представлены ведущие мировые производители активных и пассивных электронных компонентов.

Нашей специализацией является поставка электронной компонентной базы двойного назначения, продукции таких производителей как XILINX, Intel (ex.ALTERA), Vicor, Microchip, Texas Instruments, Analog Devices, Mini-Circuits, Amphenol, Glenair.

Сотрудничество с глобальными дистрибьюторами электронных компонентов, предоставляет возможность заказывать и получать с международных складов практически любой перечень компонентов в оптимальные для Вас сроки.

На всех этапах разработки и производства наши партнеры могут получить квалифицированную поддержку опытных инженеров.

Система менеджмента качества компании отвечает требованиям в соответствии с ГОСТ Р ИСО 9001, ГОСТ РВ 0015-002 и ЭС РД 009

Офис по работе с юридическими лицами:

105318, г.Москва, ул.Щербаковская д.3, офис 1107, 1118, ДЦ «Щербаковский»

Телефон: +7 495 668-12-70 (многоканальный)

Факс: +7 495 668-12-70 (доб.304)

E-mail: info@moschip.ru

Skype отдела продаж:

moschip.ru

moschip.ru_4

moschip.ru_6

moschip.ru_9