# OMRON

## Solid-State Timer

1/16 DIN Analog-Set Timer with Many Time Ranges, Operating Modes, and Aesthetics Options

- Field-selectable time ranges from 0.05 second to 300 hours
- Choose 6- or 2-function models to handle most applications
- Wide range AC supply voltage models (100 to 240 VAC) fits most applications and reduces spare parts inventories
- Three external signal inputs for remote control of the timer
- Short, 80 mm (3.15 inch) panel mounting depth with socket allows space-efficient control panel design
- Choice of light gray, medium gray or black panel covers to match panel aesthetics



H3CR

## **Ordering Information**

## ■ TIMERS

Timing functions		ON-delay, Repeat cycle (B,B2). Signal ON/OFF delay, Signal OFF-delay, Interval	ON-delay, Interval
Terminal form		11-pin round	8-pin round
Contact output	100 to 240 VAC, 50/60 Hz	H3CR-A-AC100-240	H3CR-A8-AC100-240
	12 VDC	H3CR-A-DC12	H3CR-A8-DC12
	24 VAC/VDC	H3CR-A-AC/DC24	H3CR-A8-AC/DC24
Transistor output	12 VDC	H3CR-AS-DC12	H3CR-A8S-DC12
	24 VAC/VDC	H3CR-AS-AC/DC24	H3CR-A8S-AC/DC24
Instantaneous	100 to 240 VAC, 50/60 Hz	-	H3CR-A8EL-AC120-240
output contact	24 VAC/VDC	—	H3CR-A8E-AC/DC24

## ACCESSORIES

Descripti	on		Part number
Sockets	H3CR-A,	Bottom surface or track mounting, top screw terminals	P2CF-11
	H3CR-AS timers	Back mounting, for use with Y92F-30 mounting adapter, bottom screw terminals.	P3GA-11
	H3CR-A8,	Bottom surface or track mounting, top screw terminals	P2CF-08
	H3CR-A8S timers	Back mounting, for use with Y92F-30 mounting adapter, bottom screw terminals.	P3G-08
Panel mo	ounting adapter	Fits behind panel, ideal for side-by-side installation. Use P3G□-□ sockets.	Y92F-30
		For use with products with body length measurements of 66 mm	Y92F-73
		For use with products with body length measurements of 66 mm	Y92F-74
		For use with products with body length measurements of 78 mm	Y92F-70
		For use with products with body length measurements of 78 mm	Y92F-71
Protective cover		Hard plastic cover protects against dust, dirt and water; not for use with panel covers.	
Panel covers		Light gray (Munsell No. 5Y7/1) to match case	Y92P-48GL
		Medium gray (Munsell No. 5Y5/1)	Y92P-48GM
		Black (Munsell No. N1.5)	Y92P-48GB
Time set	ting rings	Used to lock in a single setting; one ring, can be used with Y92P panel covers.	Y92S-27
		Used to lock in a setting range; two rings, can be used with Y92P panel covers.	Y92S-28
Mounting track		DIN rail, 50 cm (1.64 ft) length	PFP-50N
		DIN rail, 1 m (3.28 ft) length	PFP-100N
		End plate	PFP-M
		Spacer	PFP-S

## RANGE SELECTION

Power indicator (green flashes when timer ope lit when timer stops operating	LED) prates, Power	Operating mode display window Operation mode selector A ON-delay B Repeat cycle/signal OFF	start
Output indicator ——— (red LED)		20 B2: Repeat cycle/signal ON's C: Signal ON/OFF-delay D: Signal OFF-delay E: Interval Scale range display windows	T ra 1. 3
Time range selector — (1.2, 3, 12 or 30)	Omron H3CR-A	display window	1: 3( 0
	(set time)	(sec, min, hrs, 10h)	* 5

Time		Time units				
range	sec(onds)	min(utes)	hrs (hours)	10h (10 hours)		
1.2	0.05 to 1.2	0.12 to 1.2	0.12 to 1.2	1.2 to 12		
3	0.3 to 3	0.3 to 3	0.3 to 3	3 to 30		
12	1.2 to 12	1.2 to 12	1.2 to 12	12 to 120		
30	3 to 30	3 to 30	3 to 30	30 to 300		
0	Instantaneous output*					

\* Set to time setting knob below zero.

## Specifications \_\_\_\_\_

Part number		H3CR-A	H3CR-AS	H3CR-A8	H3CR-A8S	H3CR-A8EL/H3CR-A8E		
Supply		AC	24 V or 100 to 240 VAC, 50/60 Hz					
voltage		DC	12 V or 24 V					
Operating voltage AC		85% to 110% of rated supply voltage						
		DC	90% to 110% of rate	d supply voltage	at 12 VDC			
Power		AC	10 VA					
consump	tion	AC/DC	1.5 VA (AC), 0.8 W (	DC)				
		DC	1.3 W					
Timing fu	Inctions		ON-delay, Repeat cy	cle signal OFF/	ON-delay, Inter	val		
			start, Repeat cycle s	ignal ON start,				
			Signal OFF-delay. In	y, iterval				
Start, Re	set, Gate i	nputs	No-voltage inputs		_			
H3CR-A,	H3CR-AS		ON impedance: 1 ks	$\Omega$ max.				
			ON residual voltage:	1 V max.				
Control	Type		DPDT relay	Transistor	DPDT relay	Transistor	SPDT relay	
output	1 ypc		Di Di Tolay	(NPN/PNP)	Di Di leiay	(NPN/PNP)	(instantaneous contact)	
	Max. load	ł	5 A, 250 VAC	100 mA,	5 A, 250 VAC	100 mA,	5 A, 250 VAC	
			(p.f.=1)	30 VDC	(p.f.=1)	30 VDC	(p.f. = 1)	
	Min. load		10 mA, 5 VDC	10 mA, 5 VDC	10 mA, 5 VDC	10 mA, 5 VDC	10 mA, 5 VDC	
Residual voltage		_	2 V max.		2 V max.	—		
Repeat accuracy			±0.3% full scale max., except in 1.2 s range ±0.3% ±10 ms					
Setting e	rror		±5% full scale ±0.05 s max.					
Resetting	g system		Power OFF; external, self-resetting Power OFF					
Resetting	g time		0.1 s max.					
Indicators	S		Power ON indicator (green LED), Output ON indicator (red LED)					
Materials			Plastic case (light gr	ay Munsell 5Y7/	1) and knob (clea	ar)		
Mounting			Panel, track or surface depending on socket selected					
Connecti	ons		11-pin round socket 8-pin round socket					
Weight			Approx. 90 g (3.17 o	Approx. 90 g (3.17 oz.) Approx 110 g (3.9 oz.)				
Approval	S	UL	Recognized, File Number E41515					
		CSA	Certified, File Number LR22310					
Ambient		Operating	-10° to 55°C (14° to 131°F)					
temperature Storage		-25° to 65°C (-13° to 149°F)						
Humidity		35% to 85%						
Vibration Mechanical durability		10 to 55 Hz with 0.75 mm (0.03 in) double amplitude each in three directions						
Malfunction durability		10 to 55 Hz with 0.5 mm (0.02 in) double amplitude each in three directions						
Shock	Mechanic	al durability	100 G each in three	directions				
	Malfuncti	on durability	10 G each in three d	irections				
Variation	due to vol	tage change	±0.5% full scale max.					
Variation	due to ten	nperature change	±2% full scale max.					
Insulation resistance		100 MΩ minimum at 500 VDC						

Dielectric strength		2,000 VAC, 50/60 Hz for 1 minute between current-carrying metal parts and	
		non-current-carrying metal parts	
		2,000 VAC, 50/60 Hz for 1 minute between control output terminals and operating circuit	
		1,000 VAC, 50/60 Hz for 1 minute between contacts not located next to each other	
Service life	Electrical	100,000 operations minimum at maximum ratings	

## Engineering Data

## ■ ELECTRICAL SERVICE LIFE



## Timing Charts.

In the schematic diagrams, each thick line indicates the external wiring; shaded areas show internal connections.

### ■ H3CR-A, H3CR-AS (SIX-FUNCTION TIMERS)

#### Mode A ON-Delay

#### Signal Start/Signal Reset

Power is applied continuously. Timing starts at the leading edge of the start input. The output relay is energized when the accumulated time equals the set time. Subsequent start signals during or after timing will not be accepted. The output relay or transistor will remain energized until a reset input is applied or power is interrupted. The minimum signal input is 0.05 second.





#### Power-ON Start/ Power-OFF Reset

The start terminals are connected. Timing starts when power is applied. The output is energized when the accumulated time equals the set time. The output relay or transistor remains energized until power is disconnected or a reset input is applied. The minimum resetting time is 0.1 second.





#### Cumulative Timing Using the Gate Input with ON-Delay

When the gate signal is closed, timing is temporarily stopped. When the gate signal opens, timing resumes at the point of interruption. The gate input terminal permits the timer to sum up times  $t_1$  and  $t_2$  as shown in the timing chart.







### Modes B and B2 Repeat Cycle

#### Signal Start/Signal Reset

Power is continuously applied. The ON/OFF cycle is initiated at the leading edge of the start input.

In Mode B the output relay or transistor will be OFF for the set time and then ON for the set time, creating an operation pattern of OFF/ON/OFF.

In Mode B2 the output relay or transistor will turn ON for the set time and then OFF for the set time, creating an operation

pattern of ON/OFF/ON. This cycle will be repeated until a reset input is applied or power is disconnected. The minimum signal input time is 0.05 second.



t = set time



#### **Power-ON Start/Power OFF Reset**

The start terminals are connected. Timing starts when power is applied. The output relay or transistor operates according to mode B (OFF/ON/OFF pattern) or mode B2 (ON/OFF/ON pattern), whichever is set. The cycle repeats until a reset input is applied or power is disconnected.





#### Mode C Signal ON/OFF Delay

#### Signal ON/OFF Start/Instantaneous Operation/Time-Limit Reset

Power is continuously applied. The first timing cycle begins when the input signal is applied, the second when it is removed. The output relay or transistor is energized when the lapsed time from the first timing cycle equals the set point. The output remains energized until the lapsed time of the second timing cycle equals the set point. The minimum signal input time is 0.05 second.





t = set time t-a = less than set time

#### Power ON Start/Instantaneous Operation/Time-Limit Reset

The timing cycle starts when power is applied. When the timer reaches set point, the output status changes and holds that status until power turns OFF to reset the timer. Minimum reset time is 0.1 second.





t = set time

## Mode D Signal OFF-Delay

#### Signal Start/Instantaneous Operation/Time-Limit Reset

Power is continuously applied. The output relay is energized at the leading edge of the start input. Timing starts at the trailing edge of the start input. The output relay is de-energized when the accumulated time equals the set time. The minimum signal input time is 0.05 second.





t = set time

#### Mode D continued

#### Power-ON Start/Instantaneous Operation/Time-Limit Reset

Power is continuously applied. The output relay is energized at the leading edge of the start input. Timing starts at the trailing edge of the start input. The output is de-energized when the accumulated time equals the set time. The minimum reset time is 0.1 second.





### Mode E Interval

#### Signal Start/Instantaneous Operation/Time-Limit Reset

Timing begins on the leading edge of the start signal. The control output is only energized during timing. The timer is reset when a reset signal is applied.



#### Power ON Start/Instantaneous Operation/Time-Limit Reset

Timing begins on the leading edge of the start signal. The control output is only energized during timing. The timer is reset when power is interrupted.





#### ■ H3CR-A8 TWO-FUNCTION TIMER, DPDT CONTACT OUTPUT



#### **Power-ON Start/ Power-OFF Reset**

Timing starts when power is applied. The output is energized when the accumulated time equals the set time. The output relay remains energized until power is disconnected. The minimum resetting time is 0.1 second.

### Power ON Start/ Instantaneous Operation/Time-Limit Reset

Timing begins when power is applied. The control output is only energized during timing. The timer is reset when power is interrupted.





### ■ H3CR-A8S TWO-FUNCTION TIMER, TRANSISTOR OUTPUT



#### Power-ON Start/ Power-OFF Reset

Timing starts when power is applied. The output is energized when the accumulated time equals the set time. The output transistor remains energized until power is disconnected. The minimum resetting time is 0.1 second.

#### Power ON Start/ Instantaneous Operation/Time-Limit Reset Timing begins when power is applied. The control output is

only energized during timing. The timer is reset when power is interrupted.

#### Mode A ON-Delay





### ■ H3CR-A8EL/-A8E TWO-FUNCTION TIMER, SPDT CONTACT, INSTANTANEOUS OUTPUT



7

## Dimensions\_

Unit: mm (inch)

## ■ TIMERS

H3CR-A, H3CR-AS, H3CR-A8, H3CR-A8S, H3CR-A8E









Note: Recommended panel thickness is 1 to 3.2 mm.

Panel cutout conforms to DIN 43700.

H3CR-A8EL







Timer with Y92P Panel Cover and Y92S Setting Ring







## **Overall Mounting Depth**

Track Mounting P2CF-11

Track Mounting P2CF-08

Panel Mounting P3GA-11

Panel Mounting P3G-08









## ■ SOCKETS

11-Pin Sockets for H3CR-A, H3CR-AS

P2CF-11 Bottom surface or track mounting socket



8-Pin Sockets for H3CR-A8, H3CR-A8S, H3CR-A8E, H3CR-A8EL

P2CF-08 Bottom surface or track mounting









**Terminal arrangement** 



8

(Bottom view)

### PANEL MOUNTING ADAPTERS

#### Y92F-30 Flush Mounting Adapter

Adapter installs behind the panel. It is ideal for side by side installation. Use P3GA-11 or P3G-08 sockets.

Panel cutout









Note: Recommended panel thickness is 1 to 3.2 mm.

#### Y92F-73/-70 Flush Mounting Adapter





Y92F-74/-71 Flush Mounting Adapter



Models Y92F-73 and Y92F-74 can be used with product whose body length is 66 mm. Models Y92F-70 and Y92F-71 can be used with product whose body length is 78 mm.

88

## ■ PROTECTIVE COVER

## Y92A-48B



The hard plastic protective cover prevents accidental resetting. It also shields the front panel from dirt and water. The cover is intended for use in areas where unusual service conditions do not exist. The Y92A-48B cover cannot be used with the Y92P Panel Covers below.

## PANEL COVERS

Omron offers three colors of panel covers to match panel design aesthetics. Choose light gray (Munsell 5Y7/1) to match the case, medium gray (Munsell 5Y5/1) or black (Munsell N1.5). Panel covers conceal the time range and timing function selector knobs. The time setting rings can be used with panel covers. Y92P-48GL Light Gray Y92P-48GM Medium Gray



Y92P-48GB Black



### ■ TIME SETTING RINGS

Time setting rings allow the operator to lock in a selected, preset time. They must be used with Y92P Panel Covers. Each ring fits snugly around the time setting knob. A notch on the ring engages the tab on the panel cover to prevent setting

#### Y92S-27 Setting a Single Preset

In this example, the time setting will be locked at 10 minutes: Select timing function and set unit of measure to "min". Install the panel cover. Turn the time setting knob to 10. Align the notch on the ring with the tab then press the ring onto the time setting knob.

#### Y92S-28 Limiting the Setting Range

In this example, the timing range of 10 to 20 minutes will be locked in using the two rings in Y92S-28:

Set the timing function and set unit of measure to "min". Turn the setting knob to 10. Align the thinner ring's tab with the right side of the panel cover tab. Press the ring onto the time setting knob to set the lower limit. Turn the time setting knob to 20. Align the thicker ring's tab with the left side of the panel cover tab. Press the ring onto the time setting knob to set the upper limit.



knob travel. Omron offers two types of time setting rings in

point. The Y92S-28 pair of rings are used to lock in two set

medium gray. The Y92S-27 setting ring is used for a single set



### MOUNTING TRACK AND ACCESSORIES

PFP-100N/PFP-50N DIN Rail



## Connections

## ■ INPUT/OUTPUT FUNCTIONS

Name	Туре	Description
Start input	No-voltage contact closure	Initiates timing.
Reset input	No-voltage contact closure	Interrupts time measurement and reset the operation to start. No time measurement is made and the control output is OFF while the reset input is ON.
Gate input	No-voltage contact closure	Inhibits time measurement. Timing resumes when the gate input is turned OFF.
Control output	Relay or transistor	Turns ON and OFF when the preset value is reached, according to the operation mode selected.

## ■ CONNECTION SUMMARY

Part	Input t	erminal nu	mber (no-voltage only)	Power supply termin	al numbers	Output terminal numbe	ers		
number	Gate	Start	Reset	AC (common), DC-	AC (hot), DC+	Туре	COM	NC	NO
H3CR-A	5	6	7	2	10	Timed contact Timed contact	1 11	4 8	3 9
H3CR-AS	5	6	7	2	10	Transistor (NPN/PNP)	11	—	9
H3CR-A8	—	—	—	2	7	Timed contact Timed contact	1 8	4 5	3 6
H3CR-A8S	—	—	—	2	7	Transistor (NPN/PNP)	8	—	6
H3CR-A8EL H3CR-A8E	_	-	—	2	7	Timed contact Instantaneous contact	1 8	4 5	3 6

## ■ CONTACT SIGNAL INPUTS

#### **Input Signal Requirements**

Resistance	1 kΩ max.
Residual voltage	1 V max. when the contact makes
Contact type	Capable of switching 80 μA at 5 VDC

#### H3CR-A

- Start input contact between terminals 2 and 6.
- · Reset input contact between terminals 2 and 7.
- Gate input contact between terminals 2 and 5.

## ■ SOLID-STATE SIGNAL INPUTS

#### Input Signal Requirements

Input type	Open collector transistor
Voltage when collector is OFF	20 V min.
Saturated voltage when transistor is ON	1 V max.
Collector current	50 mA min.
Input current between collector and base	0.5 μA max.
Resistance when transistor is ON	1 kΩ max.
Residual voltage when transistor is ON	2 V max.
Resistance when transistor is OFF	200 kΩ min.

#### H3CR-AS

Solid-state input signal terminal connections are the same as those for contact signal inputs.

## Installation

## ■ WIRING PRECAUTIONS (H3CR-A)

Except for the wiring of the power supply circuit, avoid laying input signal wires in parallel or in the same conduit with high tension or power lines. Use shielded wires or wiring with independent metal conduits for the shortest possible distance.

Never touch the input terminals while power is being applied to the timer to prevent electric shock.

An AC power supply can be connected to the power input terminals without regard to polarity. A DC power supply must be connected to the power input terminals as designated according to the polarity of the terminals.

A DC power supply can be connected if its ripple factor is 20% or less and the mean voltage is within the rated operating voltage of the timer.

Connect the power supply voltage through a relay or switch in such a way that the voltage reaches a fixed value at once, otherwise the timer may not reset or a timing error could result.

## ■ WIRING TRANSISTOR OUTPUTS (H3CR-AS, H3CR-A8S)

The optoisolated output from the transistor allows both NPN and PNP input devices to be connected to the H3CR's output. Connect the load to the transistor output (terminals 9 and 11) according to the NPN or PNP input requirements of the device.

#### For NPN Input Devices





#### Solid-State Inputs (NPN or PNP with voltage)

ര

Power

Proximity and photoelectric sensors often have NPN or PNP type solid-state output circuits and rated supply voltages ranging from 6 to 30 VDC. A typical NPN connection is shown below.





Use an isolation transformer for the power supply of an input device. The transformer's primary and secondary windings should be mutually isolated and the secondary winding not grounded.



## SETTING CHANGES DURING OPERATION

Do not change the time unit, time range or operation mode while the timer is in operation. This will cause a malfunction.

### CONNECTIONS

#### **Parallel Connections**

When timers are connected in parallel, be sure to connect the same number terminals to each other.

#### **Proper Input Connections**

The neutral or common of the power supply is connected to terminal 2 of the timer. This terminal is also used as the common for the input signals. Terminal 10 should be connected to the "hot" or positive of the power supply. **Do not** use terminal 10 as the common terminal or the timer will be damaged.



#### **Proper Output Connections**

Design your control circuit using the output relay contacts to switch the load. **Never switch a load with the contact that is being used as an input signal.** The timer's circuitry may be damaged. More importantly, it is unsafe electrical practice to control a load by switching the common or neutral.

## Operation\_\_\_\_\_

#### SELECTING TIME RANGES

The time unit is selected by turning the rotary switch located on the front panel in the lower right corner. Choose seconds, minutes, hours or 10 hours. The time range is selected by turning the rotary switch in the lower left corner. Dial digits appear in the windows around the time setting knob. The table below shows dial digits that appear in the windows for each time range. Use a small flat-blade or Phillips screwdriver.

Time		Time units			
range	sec(onds)	min(utes)	hrs (hours)	10h (10 hours)	
1.2	0.05 to 1.2	0.12 to 1.2	0.12 to 1.2	1.2 to 12	
3	0.3 to 3	0.3 to 3	0.3 to 3	3 to 30	
12	1.2 to 12	1.2 to 12	1.2 to 12	12 to 120	
30	3 to 30	3 to 30	3 to 30	30 to 300	
0	Instantaneous output*				

\* Set the time setting knob to below zero. Use the instantaneous output to check sequential operation of input and output devices attached to the timer.



## SELECTING OPERATION MODES

The operation mode of H3CR timers is selected by turning the rotary switch in the top right corner of the front panel. Select the mode using a small flat-blade or Phillips screwdriver. Note that H3CR-A8, H3CR-A8S, H3CR-A8E and H3CR-A8EL only have Mode A (ON-delay) and Mode E (Interval).

Mode	Function
A	ON-delay
В	Repeat cycle/signal OFF start
B2	Repeat cycle/signal ON start
С	Signal ON/OFF-delay
D	Signal OFF-delay
E	Interval

## ■ CAUTIONS

Do not change the time unit or time range while the timer is in operation. Otherwise, the timer may malfunction or be damaged. Be sure to turn off the power supply to the timer before changing any of the selections.

## Mounting\_

## PANEL MOUNTING

#### Using Y92F-30 Adapter

Insert the timer through the panel cutout. Push the Y92F-30 adapter from the rear of the timer as far forward toward the panel as possible. Wire the P3G $\Box\Box$  socket, then push it onto the rear of the timer. Then tighten the two retaining screws. To release the adapter, lift the tab at the rear of the adapter.

Molded tab





Molded tab



Panel cutout for side-by-side mounting of two timers



Several timers may be panel mounted close together using Y92F-30 adapter as shown here. When mounting two or more timers in a vertical line, arrange the adapters so that their molded tabs are positioned on the right and left sides. When mounting two or more timers in a horizontal line, arrange the adapters so that their molded tabs are positioned on the top and bottom sides.

## TRACK MOUNTING

### Using P2CF-DD Socket

#### Mounting

The P2CF- D socket has two hooks that secure the timer to the socket. Be sure to allow at least 20 mm (0.79 in) clearance above and below the socket to gain access and to release the hooks for servicing and maintenance. Insert timer into the socket. Latch hooks. Then clip rear of the socket to the track. Push the bottom onto the track until the latch hooks securely.



#### Removal

Pull the latch on the socket with a flat-blade screwdriver and remove the timer and socket as one unit.

NOTE: DIMENSIONS ARE IN MILLIMETERS. To convert millimeters to inches, divide by 25.4

OMRON ELECTRONICS, INC. One East Commerce Drive Schaumburg, IL 60173 1-800-55-OMRON

OMRON CANADA, INC.

885 Milner Avenue Scarborough, Ontario M1B 5V8 **416-286-6465** 

Cat. No. GC TI8

11/97

Printed in the U.S.A.





Общество с ограниченной ответственностью «МосЧип» ИНН 7719860671 / КПП 771901001 Адрес: 105318, г.Москва, ул.Щербаковская д.З, офис 1107

## Данный компонент на территории Российской Федерации

Вы можете приобрести в компании MosChip.

Для оперативного оформления запроса Вам необходимо перейти по данной ссылке:

## http://moschip.ru/get-element

Вы можете разместить у нас заказ для любого Вашего проекта, будь то серийное производство или разработка единичного прибора.

В нашем ассортименте представлены ведущие мировые производители активных и пассивных электронных компонентов.

Нашей специализацией является поставка электронной компонентной базы двойного назначения, продукции таких производителей как XILINX, Intel (ex.ALTERA), Vicor, Microchip, Texas Instruments, Analog Devices, Mini-Circuits, Amphenol, Glenair.

Сотрудничество с глобальными дистрибьюторами электронных компонентов, предоставляет возможность заказывать и получать с международных складов практически любой перечень компонентов в оптимальные для Вас сроки.

На всех этапах разработки и производства наши партнеры могут получить квалифицированную поддержку опытных инженеров.

Система менеджмента качества компании отвечает требованиям в соответствии с ГОСТ Р ИСО 9001, ГОСТ РВ 0015-002 и ЭС РД 009

## Офис по работе с юридическими лицами:

105318, г.Москва, ул.Щербаковская д.З, офис 1107, 1118, ДЦ «Щербаковский»

Телефон: +7 495 668-12-70 (многоканальный)

Факс: +7 495 668-12-70 (доб.304)

E-mail: info@moschip.ru

Skype отдела продаж: moschip.ru moschip.ru\_4

moschip.ru\_6 moschip.ru\_9