NJ-Series Power Supply Unit

Powerful power supply unit to supply stable power to the NJ-series controller.

Stable power supply is available from the NJ-series CPU Unit to each I/O Unit via the dedicated bus. Lineups are provided for AC and DC input types with 30 W output.



NJ-PD3001

Features

- AC input type (100 to 240 VAC)/DC input type (24 VDC) with 30 W output allows power supply to large-scale configurations.
- Operating output contact indicates the CPU operation status (available in all models).

Ordering Information

International Standards

- The standards are abbreviated as follows: U: UL, U1: UL(Class I Division 2 Products for Hazardous Locations), C: CSA, UC: cULus, UC1: cULus (Class I Division 2 Products for Hazardous Locations), CU: cUL, N: NK, L: Lloyd, and CE: EC Directives.
- Contact your OMRON representative for further details and applicable conditions for these standards.

Power Supply Units

| Product Name | | Dowor | Output current | | Output capacity | Options | | | | |
|-------------------------|--|-------------------|-----------------------------|------------------------------|-------------------------|--------------------------------------|---------------|------------------------------------|-----------|------------|
| | | supply voltage | 5-VDC output capacity | 24-VDC output capacity | Total power consumption | 24-VDC service power supply | RUN output | Maintenance forecast monitor | Model | Standards |
| AC Power Supply Unit | | 100 to 240 VAC | 604 | 10.4 | 20.14 | No | Yee | No | NJ-PA3001 | UC1, N, L, |
| DC Power Supply Unit | | 24 VDC | 0.0 A | 1.0 A | 30 W | INO | 185 | NO | NJ-PD3001 | CE |

Note: Power supply units for the CJ-Series cannot be used as a power supply for a CPU rack of the NJ system or as a power supply for an expansion rack.

Accessories

There is no accessory for the NJ-series Power Supply Unit.

Sysmac is a trademark or registered trademark of OMRON Corporation in Japan and other countries for OMRON factory automation products. Other company names and product names in this document are the trademarks or registered trademarks of their respective companies.

NJ-PA/PD

General Specification

| Item | Specifications | | | | |
|--|---|---|--|--|--|
| Model | NJ-PA3001 NJ-PD3001 | | | | |
| Supply voltage | 100 to 240 VAC (wide-range), 50/60 Hz | 24 VDC | | | |
| Operating voltage and frequency ranges | 85 to 264 VAC, 47 to 63 Hz | 19.2 to 28.8 VDC | | | |
| Power consumption | 120 VA max. | 60 W max. | | | |
| Inrush current *1 | At 100 VAC: 20 A/8 ms max. for cold start at room temperature At 200 VAC: 40 A/8 ms max. for cold start at room temperature | At 24 VDC: 30 A/20 ms max. for cold start | | | |
| Output capacity *2 | 5 VDC, 6.0 A (including supply to CPU Unit using CPU Rack) 5 VDC, 6.0 A (using Expansion Rack) 24 VDC, 1.0 A Total: 30 W max. | | | | |
| Output terminal (service supply) | Not provided | | | | |
| RUN output *3 | Contact configuration: SPST-NO Switch capacity: 250 VAC, 2 A (resistive load) 120 VAC, 0.5 A (inductive load), 24 VDC, 2A (resistive load) | | | | |
| Replacement notification function | Not provided | | | | |
| Insulation resistance *4 | 20 $\text{M}\Omega$ min. (at 500 VDC) between AC external and GR terminals | 20 $M\Omega$ min. (at 500 VDC) between DC external and GR terminals | | | |
| Dielectric 2,300 VAC 50/60 Hz for 1 min between AC external and GR terminals Leakage current: 10 mA max. | | 1,000 VAC 50/60 Hz for 1 min between DC external and GR terminals Leakage current: 10 mA max. | | | |
| Noise immunity | 2 kV on power supply line (Conforms to IEC 61000-4-4.) | | | | |
| Vibration resistance | 5 to 8.4 Hz, 3.5-mm amplitude, 8.4 to 150 Hz, acceleration: 9.8 m/s coefficient factor 10 = total time 100 min) (according to IEC 60068- | $^{\rm s^2}$ in X, Y, and Z directions for 100 min (Time coefficient: 10 min \times 2-6) | | | |
| Shock resistance | 147 m/s ² 3 times each in X, Y, and Z directions (Relay Output Unit: 100 m/s ²) (according to IEC 60068-2-27) | | | | |
| Ambient operating temperature | 0 to 55°C | | | | |
| Ambient operating humidity | 10% to 90% (with no condensation) | | | | |
| Atmosphere | Must be free from corrosive gases. | | | | |
| Ambient storage temperature | -20 to 75°C | | | | |
| Grounding | Less than 100 Ω | | | | |
| Enclosure | Mounted in panel | | | | |
| Weight | 470 g max. | 490 g max. | | | |
| CPU Rack dimensions | 174.7 to 484.7 × 90 × 90 mm (W × D × H) (not including cables) W = 70 (Power Supply Unit) + 90 (CPU Unit) + 20 × n + 31 × m + 14.7 (end cover) n is the number of 32-point I/O Units or I/O Control Units and m is the number of other Units. | | | | |
| Safety measures | Conforms to cULus, EC Directives, NK and LR. | | | | |

*1. The AC and DC values above are given for a cold start, and the AC values are at room temperature. The AC inrush control circuit uses a thermistor element with a low-temperature current control characteristic. If the ambient temperature is high or the Controller is hot-started, the thermistor will not be sufficiently cool, and the inrush current given in the table may be exceeded by up to twice the given value. The DC inrush control circuit uses a capacitor-charging delay circuit. If the power is OFF for only a short time for a hot-start, the capacitor will not sufficiently discharge and the inrush current given in the table may be exceeded by up to twice the given value. An inrush current of approximately 4 A may occur and continue for 1 s when the power is turned ON. When selecting fuses, breakers, and external DC power supply devices for external circuits, allow sufficient margin in shut-off performance.

*2. Internal components in the Power Supply Unit will deteriorate or be damaged if the Power Supply Unit is used for an extended period of time exceeding the power supply output capacity or if the outputs are shorted.

*3. Supported only when mounted to CPU Rack.

*4. The tests can also be performed with the LG terminal and GR terminal connected to each other.

*5. Change the applied voltage gradually using the adjuster on the Tester. If the full dielectric strength voltage is applied or turned OFF using the switch on the Tester, the generated impulse voltage may damage the Power Supply Unit.

External Interface

NJ-PA3001

NJ-PD3001



AC Input

Supply 100 to 240 VAC (allowable: 85 to 264 VAC). The NJ-PA3001 has a wide input range, so it does not have voltage switching terminals.

DC Input

Supply 24 VDC (allowable: 19.2 to 28.8 VDC.)

LG

Ground to a resistance of 100 Ω or less to increase noise resistance and avoid electric shock.

GR

Ground to a resistance of 100 Ω or less to avoid electric shock.

RUN Output

The internal contacts for the RUN output turn ON when the CPU Unit is in RUN status.

Wiring

•About Power Supply

For AC/DC power supply

| Recommended wire | AWG 14 to 20 |
|--------------------|--|
| diameter | (Cross section 0.517 to 2.08 mm ²) |
| For arounding wire | |

| Recommended wire diameter | 2 mm ² or thicker |
|------------------------------|------------------------------|

Crimp Terminals

The terminals on the Power Supply Unit are M4, self-raising terminals with screws.

Crimp Terminals for AC Power Supplies



Crimp Terminals for DC Power Supplies





Precautions for Use

Compatible CPU Models

NJ-PA3001/NJ-PD3001 are dedicated for NJ-series.

Please make sure to use NJ-PA3001/NJ-PD3001 for all products including NJ-series CPU rack and expansion rack.

Power Supply Units Current Consumption

Checking Current Consumption and Power Consumption

After selecting a Power Supply Unit based on considerations such as the power supply voltage, calculate the current and power requirements for each Rack.

Condition 1: Current Requirements

There are two voltage groups for internal power consumption: 5 V and 24 V. Current consumption at 5 V (internal logic power supply) Current consumption at 24 V (relay driving power supply)

Condition 2: Power Requirements

For each Rack, the upper limits are determined for the current and power that can be provided to the mounted Units. Design the system so that the total current consumption for all the mounted Units does not exceed the maximum total power or the maximum current supplied for the voltage groups shown in the following tables.

The maximum current and total power supplied for CPU Racks and Expansion Racks according to the Power Supply Unit model are shown below. **Note: 1.** For CPU Racks, include the CPU Unit current and power consumption in the calculations. When expanding, also include the current and

power consumption of the I/O Control Unit in the calculations. 2. For Expansion Racks, include the I/O Interface Unit current and power consumption in the calculations.

| Dowor | Ма | (C) | | | |
|-----------------|-------------------------|-------------------------------|------------|---------------------------------|--|
| Supply Units | (A) 5-VDC CPU Racks* | (A)5-VDC Expansion Rack | (B) 24 VDC | Max. total power supplied | |
| NJ-PA3001 | 6.0 A | 6.0 A | 1.0 A | 30 W | |
| NJ-PD3001 | 6.0 A | 6.0 A | 1.0 A | 30 W | |

Conditions 1 and 2 below must be satisfied.

Condition 1: Maximum Current

(1) Total Unit current consumption at 5 V \leq (A) value (2) Total Unit current consumption at 24 V \leq (B) value

Condition 2: Maximum Power

(1) \times 5 V + (2) \times 24 V \leq (C) value

* Including supply to the CPU Unit.

OMRON

Example: Calculating Total Current and Power Consumption

Example: When the Following Units are Mounted to a NJ-Series CPU Rack Using a NJ-PA3001 Power Supply Unit

| Unit type | Madal | Quantity | Voltage group | | |
|--------------------------------|------------|--------------|---|------------------------|--|
| onit type | woder | Quantity | 5 V | 24 V | |
| CPU Unit | NJ501-1500 | NJ501-1500 1 | | - | |
| I/O Control Unit | CJ1W-IC101 | 1 | 0.02 A | - | |
| Basic I/O Units (Input Units) | CJ1W-ID211 | 2 | 0.08 A | - | |
| | CJ1W-ID231 | 2 | 0.09 A | - | |
| Basic I/O Units (Output Units) | CJ1W-OC201 | CJ1W-OC201 2 | | 0.048 A | |
| Special I/O Unit | CJ1W-DA041 | 1 | 0.12 A | - | |
| CPU Bus Unit | CJ1W-SCU22 | CJ1W-SCU22 1 | | - | |
| Current consumption | To | tal | 1.9 A+0.02 A+0.08 A × 2+0.09 A × 2+0.09 A × 2+0.12 A+0.28 | 0.048 A × 2 | |
| | Re | sult | 2.84 A (≤ 6.0 A) | 0.096 A (≤ 1.0 A) | |
| Power consumption | Total | | 2.84 × 5 V = 14.2 W | 0.096 A × 24 V = 2.3 W | |
| | Re | sult | 14.2 W + 2.3 W = 16.5 W (≤ 30 W) | | |

Using the Sysmac Studio to Display Current Consumption and Width

CPU Rack and Expansion Rack current consumption and width can be displayed by selecting *CPU/Expansion Racks* from the *Configurations* and Setup in the Multiview Explorer. If the capacity of the Power Supply Unit is exceeded, an error icon is displayed in the power supply unit of a corresponding rack. For details, refer to Sysmac Studio Operation manual (W504).

NJ-PA/PD

(Unit: mm)

Dimensions

NJ-PA3001





NJ-PD3001





Related Manuals

| Manual name | Cat. No. | Model numbers | Application | Description |
|--|----------|---------------|---|---|
| NJ-series CPU Unit Hardware User's Manual | W500 | NJ501- | Learning the basic specifications of the NJ-series CPU Units, including introductory information, designing, installation, and maintenance. Mainly hardware information is provided. | An introduction to the entire NJ-series system is provided along with the following information on a Controller built with an NJ501 CPU Unit. • Features and system configuration • Introduction • Part names and functions • General specifications • Installation and wiring • Maintenance and inspection Use this manual together with the <i>NJ-series</i> <i>CPU Unit Software User's Manual</i> (Cat. No. W501). |

Read and Understand This Catalog

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

Warranty and Limitations of Liability

WARRANTY

OMRON's exclusive warranty is that the products are free from defects in materials and workmanship for a period of one year (or other period if specified) from date of sale by OMRON.

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, REGARDING NON-INFRINGEMENT, MERCHANTABILITY, OR FITNESS FOR PARTICULAR PURPOSE OF THE PRODUCTS. ANY BUYER OR USER ACKNOWLEDGES THAT THE BUYER OR USER ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. OMRON DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED.

LIMITATIONS OF LIABILITY

OMRON SHALL NOT BE RESPONSIBLE FOR SPECIAL, INDIRECT, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED ON CONTRACT, WARRANTY, NEGLIGENCE, OR STRICT LIABILITY.

In no event shall the responsibility of OMRON for any act exceed the individual price of the product on which liability is asserted.

IN NO EVENT SHALL OMRON BE RESPONSIBLE FOR WARRANTY, REPAIR, OR OTHER CLAIMS REGARDING THE PRODUCTS UNLESS OMRON'S ANALYSIS CONFIRMS THAT THE PRODUCTS WERE PROPERLY HANDLED, STORED, INSTALLED, AND MAINTAINED AND NOT SUBJECT TO CONTAMINATION, ABUSE, MISUSE, OR INAPPROPRIATE MODIFICATION OR REPAIR.

Application Considerations

SUITABILITY FOR USE

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of products in the customer's application or use of the products.

At the customer's request, OMRON will provide applicable third party certification documents identifying ratings and limitations of use that apply to the products. This information by itself is not sufficient for a complete determination of the suitability of the products in combination with the end product, machine, system, or other application or use.

The following are some examples of applications for which particular attention must be given. This is not intended to be an exhaustive list of all possible uses of the products, nor is it intended to imply that the uses listed may be suitable for the products:

- · Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this catalog.
- Nuclear energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equipment, and installations subject to separate industry or government regulations.
- · Systems, machines, and equipment that could present a risk to life or property.

Please know and observe all prohibitions of use applicable to the products.

NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCTS ARE PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

PROGRAMMABLE PRODUCTS

OMRON shall not be responsible for the user's programming of a programmable product, or any consequence thereof.

Disclaimers

CHANGE IN SPECIFICATIONS

Product specifications and accessories may be changed at any time based on improvements and other reasons.

It is our practice to change model numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the products may be changed without any notice. When in doubt, special model numbers may be assigned to fix or establish key specifications for your application on your request. Please consult with your OMRON representative at any time to confirm actual specifications of purchased products.

DIMENSIONS AND WEIGHTS

Dimensions and weights are nominal and are not to be used for manufacturing purposes, even when tolerances are shown.

PERFORMANCE DATA

Performance data given in this catalog is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of OMRON's test conditions, and the users must correlate it to actual application requirements. Actual performance is subject to the OMRON Warranty and Limitations of Liability.

ERRORS AND OMISSIONS

The information in this document has been carefully checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical, or proofreading errors, or omissions.

2011.12

OMRON Corporation Industrial Automation Company

In the interest of product improvement, specifications are subject to change without notice.

http://www.ia.omron.com/

Mouser Electronics

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

Omron: <u>NJ-PA3001</u> <u>NJ-PD3001</u>





Общество с ограниченной ответственностью «МосЧип» ИНН 7719860671 / КПП 771901001 Адрес: 105318, г.Москва, ул.Щербаковская д.З, офис 1107

Данный компонент на территории Российской Федерации

Вы можете приобрести в компании MosChip.

Для оперативного оформления запроса Вам необходимо перейти по данной ссылке:

http://moschip.ru/get-element

Вы можете разместить у нас заказ для любого Вашего проекта, будь то серийное производство или разработка единичного прибора.

В нашем ассортименте представлены ведущие мировые производители активных и пассивных электронных компонентов.

Нашей специализацией является поставка электронной компонентной базы двойного назначения, продукции таких производителей как XILINX, Intel (ex.ALTERA), Vicor, Microchip, Texas Instruments, Analog Devices, Mini-Circuits, Amphenol, Glenair.

Сотрудничество с глобальными дистрибьюторами электронных компонентов, предоставляет возможность заказывать и получать с международных складов практически любой перечень компонентов в оптимальные для Вас сроки.

На всех этапах разработки и производства наши партнеры могут получить квалифицированную поддержку опытных инженеров.

Система менеджмента качества компании отвечает требованиям в соответствии с ГОСТ Р ИСО 9001, ГОСТ РВ 0015-002 и ЭС РД 009

Офис по работе с юридическими лицами:

105318, г.Москва, ул.Щербаковская д.З, офис 1107, 1118, ДЦ «Щербаковский»

Телефон: +7 495 668-12-70 (многоканальный)

Факс: +7 495 668-12-70 (доб.304)

E-mail: info@moschip.ru

Skype отдела продаж: moschip.ru moschip.ru_4

moschip.ru_6 moschip.ru_9